

# Airport Hangar Inspection Checklist

Fire and Life Safety sample checklist for airport hangars.



## Electrical

- ☐ Discontinue use of extension cords in lieu of permanent wiring.
- ☐ Discontinue use of multi-plug adapters in series.
- ☐ Remove extension cords through openings, affixed to buildings, or attached in series.
- ☐ Maintain wiring in good condition and protect from damage.
- ☐ Discontinue use of wiring not in conduit.
- ☐ Provide cover plates.
- ☐ Replace all damaged/spliced electrical wiring.
- ☐ Electrical panel and equipment shall have a minimum of 36" clearance front, 30" sides and 76" height.

## Exiting and Housekeeping

- ☐ Flammable liquids must be stored in original containers or closed metal cans.
- ☐ Store any rubbish exceeding the capacity of a 5-gallon bucket in an approved container.
- ☐ Provide 30" clearance from heat producing appliances and combustible material.
- ☐ Remove combustible storage, waste, trash or weeds.
- ☐ Remove or store waste material and oily rags in approved/listed closed metal container.
- ☐ Provide metal drip pans located under the engines of all aircraft.

- ☐ Provide and post NO SMOKING signs.

## Fire Protection

- ☐ Extinguishers must be serviced every 6 years and inspected annually
- ☐ Extinguishers must be accessible and located appropriately.
- ☐ Maintain integrity of occupancy and area separation walls.

## Storage

- ☐ Remove storage from exits, aisles, corridors, and under stairs.
- ☐ Reduce storage height to at least 2 feet below ceiling in buildings not protected by sprinklers.
- ☐ Secure and identify compressed gas cylinders.

**Make and Share Free Checklists**  
[checkli.com](https://checkli.com)