Airport Hangar Inspection Checklist

Fire and Life Safety sample checklist for airport hangars.



Electrical

- [ ] Discontinue use of extension cords in lieu of permanent wiring.
- [ ] Discontinue use of multi-plug adapters in series.
- [ ] Remove extension cords through openings, affixed to buildings, or attached in series.
- [ ] Maintain wiring in good condition and protect from damage.
- [ ] Discontinue use of wiring not in conduit.
- [ ] Provide cover plates.
- [ ] Replace all damaged/spliced electrical wiring.
- [ ] Electrical panel and equipment shall have a minimum of 36” clearance front, 30” sides and 76” height.

Exiting and Housekeeping

- [ ] Flammable liquids must be stored in original containers or closed metal cans.
- [ ] Store any rubbish exceeding the capacity of a 5-gallon bucket in an approved container.
- [ ] Provide 30” clearance from heat producing appliances and combustible material.
- [ ] Remove combustible storage, waste, trash or weeds.
- [ ] Remove or store waste material and oily rags in approved/listed closed metal container.
- [ ] Provide metal drip pans located under the engines of all aircraft.

- [ ] Provide and post NO SMOKING signs.

Fire Protection

- [ ] Extinguishers must be serviced every 6 years and inspected annually
- [ ] Extinguishers must be accessible and located appropriately.
- [ ] Maintain integrity of occupancy and area separation walls.

Storage

- [ ] Remove storage from exits, aisles, corridors, and under stairs.
- [ ] Reduce storage height to at least 2 feet below ceiling in buildings not protected by sprinklers.
- [ ] Secure and identify compressed gas cylinders.

Make and Share Free Checklists
checkli.com