
Tension Grid and Catwalk Safety Inspection Checklist

To be completed quarterly or annually.



Grid & Catwalk Access and Fall Prevention

- [ ] Access is controlled and restricted to unauthorized personnel.
- [ ] Fall prevention or arrest systems are in place and functional on fixed ladders.
- [ ] Guardrails (top and mid rails) and toeboards are secure on all tension grids and catwalks.
- [ ] The gates/guards on ladder access openings are kept closed.

Storage

- [ ] Counter weights are stacked below the top level of the toeboards.
- [ ] Counter weights are evenly distributed along the loading platform.
- [ ] Signs are present to warn against stacking counter weights higher than the top of the toeboards.
- [ ] Tension grids and catwalks are free of other stored items.
- [ ] Tension grid and catwalks are free of graffiti.

Rigging Ropes, Cables, Chains, Hoists, and Winches

- [ ] Light and audio fixtures/equipment is secured to battens with secondary restraints.
- [ ] Rigging ropes and cables are in good condition and are routinely inspected by knowledgeable staff.
- [ ] Rigging ropes and cables are inspected every five years by knowledgeable outside agency.

- [ ] Hoists and beams are clearly labeled to indicate maximum capacities.
- [ ] Line set weight-capacity signs are present on the loading bridge.

Personal Protective Equipment & Injury Prevention

- [ ] Personnel are using personal fall protection devices appropriately.
- [ ] Personnel are wearing hard hats with chin straps in head bump areas.
- [ ] Personnel have tied off their tools.
- [ ] Personnel are wearing other personal protective equipment as required for the work.
- [ ] Safety and warning signs are present; i.e., head bump, keep access gate closed, etc.

Fire Prevention, Emergency Exits, Emergency Response

- [ ] Access is controlled and restricted to unauthorized personnel.
- [ ] Fall prevention or arrest systems are in place and functional on fixed ladders.

Electrical Hazards

- [ ] Cords and plugs in good condition; no exposed or patched wires.
- [ ] Power cords are not wrapped around structural supports.
- [ ] Power cords and communication wires are well organized.
- [ ] Power cables are placed to the edges of catwalks and out of walking areas.

Make and Share Free Checklists
checkli.com