

# Great Plains School

## commons area

- ☐ install louver in mezzanine
- ☐ hang kitchen hood
- ☐ hook up fresh air to hood
- ☐ exhaust goose neck on roof
- ☐ finish exhaust duct from old louver
- ☐ reroute bathroom exhaust out the side wall north side
- ☐ install fire/smoke damper in wall by kitchen
- ☐ remove. and reinstall cabinet unit heater in classroom
- ☐ cut in curb for fresh air to existing heating unit in old part of school
- ☐ finish demo of old louver in mech. room
- ☐ run dishwasher ductwork closer to new dishwasher
- ☐ finish running pipe in entryway of school on the north end
- ☐ set unit on curb outside
- ☐ layout holes to the theater
- ☐ see if dishwasher hood is in warehouses
- ☐ fresh air ductwork needs to be insulated before paint
- ☐ measure grease duct once kitchen hood is hung
- ☐ see if mills will glue stainless sheets on for us
- ☐ talk to electricians about unhooking unit heater in classroom
- ☐ line up crane for setting unit outside on curb
- ☐ go over new hole layout for louver for unit heater
- ☐ find out kitchen hood hight
- ☐ line up roofer for new fresh air curb on old building
- ☐ go over slot diffusers in Commons area with ceiling guy